



Ref. Certif. No.

SG PSB-LE-06265

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Power supply (LED Driver)																		
Name and address of the applicant	<b>Signify (China) Investment Co., Ltd.</b> Building No. 9, Lane 888, Tianlin Road Minhang 200233 Shanghai PEOPLE'S REPUBLIC OF CHINA																		
Name and address of the manufacturer	Signify (China) Investment Co., Ltd. Building No. 9, Lane 888, Tianlin Road, Minhang, 200233 Shanghai, PEOPLE'S REPUBLIC OF CHINA																		
Name and address of the factory																			
Ratings and principal characteristics	<table><tbody><tr><td>Rated Voltage:</td><td>220-240V~</td></tr><tr><td>Rated Frequency:</td><td>50/60Hz</td></tr><tr><td>Rated input current:</td><td>See model list</td></tr><tr><td>Rated output:</td><td>See model list</td></tr><tr><td>Protection against Electric Shock:</td><td>Class II; SELV</td></tr><tr><td>Degree of Protection:</td><td>IP20</td></tr><tr><td>Method of Installation:</td><td>Independent</td></tr><tr><td>Type of Output:</td><td>Constant voltage</td></tr><tr><td>ta, tc:</td><td>See model list</td></tr></tbody></table>	Rated Voltage:	220-240V~	Rated Frequency:	50/60Hz	Rated input current:	See model list	Rated output:	See model list	Protection against Electric Shock:	Class II; SELV	Degree of Protection:	IP20	Method of Installation:	Independent	Type of Output:	Constant voltage	ta, tc:	See model list
Rated Voltage:	220-240V~																		
Rated Frequency:	50/60Hz																		
Rated input current:	See model list																		
Rated output:	See model list																		
Protection against Electric Shock:	Class II; SELV																		
Degree of Protection:	IP20																		
Method of Installation:	Independent																		
Type of Output:	Constant voltage																		
ta, tc:	See model list																		
Trademark / Brand (if any)	PHILIPS																		
Model/type Ref.	Xi LED Transformer 30W TD 24VDC G2, Xi LED Transformer 100W TD 24VDC G2, Xi LED Transformer 60W TD 24VDC G2, Xi LED Transformer 200W TD 24VDC G2																		
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016																		
as shown in the Test Report Ref. No. which forms part of this certificate	085-240604101-000																		

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 102213 0264 Rev. 00

Date, 2024-11-08

( Shaochang Liu )

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-06265

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Trademark / Brand (Image)

**PHILIPS**

Model list:

Item	Model	Rated input current (A)	Power factor	Rated output voltage (Vdc)	Rated output current (A)	Rated output power (W)	ta/tc (°C)	Dimming method
1	Xi LED Transformer 30W TD 24VDC G2	0.19	0.95	24	0.5-1.25	12-30	-25 to 45/80	DALI
2	Xi LED Transformer 100W TD 24VDC G2	0.6	0.95	24	1.25-4.17	30- 100	-25 to 45/90	DALI
3	Xi LED Transformer 60W TD 24VDC G2	0.35	0.95	24	1-2.5	24-60	-25 to 45/80	DALI
4	Xi LED Transformer 200W TD 24VDC G2	1.2	0.95	24	2.5-8.34	60- 200	-25 to 45/85	DALI

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 102213 0264 Rev. 00

Date, 2024-11-08

( Shaochang Liu )

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore