

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the factory

When more than one factory☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: Uin: 220-240 V; fn: 50/60 Hz; lin: 0,56-0,51 A; Pin: 123 W; PF: 0,95;

Uoutput: 50-220 Vdc, Uout = 270 V max;

Irated: 200-1050 mA; Prated: 110 W; tc: 80 °C; Built-in

Trademark / Brand (if any)

PHILIPS or SIGNIFY

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xi CR 110W 0.2-1.05A SDMP 230V C133 sXt

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

National differences:

AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

6219098.50(A-B) and 6219098.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-04-08

Signature: Susan Lehner