

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Lighting Controller/Sensor

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the factory

Signify Poland Sp. z o.o.
Ul przemyslowa 29, 64-920 Pila, Poland*When more than one factory*☒ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: Uin: 12-22 Vdc; Pin: 140 mW;
ta: -30...+65 °C; tc: max 65 °C; IP65; Class II;

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

SNHaxyz h

Additional information

☒ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-11:2001 and IEC 61347-2-11:2001/AMD1:2017

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6182628.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-06-11

Signature: K. Lin



Ref. Certif. No.

NL-108112

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Fideltronik Poland Sp. z o.o.
Ul Beniowskiego 1, 34-200 Sucha Beskidzka, Poland

Additional information

Note:
SNHaxyz h
a= maybe not used or capital "B", indicating the location of the sensor input cable, not used indicating the cable enters at the side of the sensor; B indicating the cable enters at the bottom of the sensor.
x= One Arabic number, maybe 2 or 4; 2 means RF sensor with Daylight/occupancy function; 4 means RF-only sensor.
y= One Arabic number 1, means Bluetooth LE vertical link.
z= One Arabic number for the product version, from 0 to 9.
h= Two letters for the firmware version, maybe use MC or IA.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2024-06-11

Signature: K. Lin