

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, Netherlands

Name and address of the factory

When more than one factory☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: Input: 220-240 V 50/60 Hz 0,11-0,27 A; 186-250 V 0 Hz 0,13-0,32 A. Output: 0,54 -1,5 A 20-50 W

Trademark / Brand (if any)


PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium 20W WH 0.15-0.5A 54V SR Is 230V,
Xitanium 20W WH 0.15-0.5A 54V SR S 230V,
Xitanium 36W WH 0.3-1.05A 54V SR Is 230V,
Xitanium 36W WH 0.3-1.05A 54V SR S 230V,
Xitanium 50W WH 0.7-1.5A 54V SR Is 230V and
Xitanium 50W WH 0.7-1.5A 54V SR S 230V

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020


National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

3509646.250 and 3509646.251

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-09-04

Signature: MT Tonsi