



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC24123440438

Valid from: Jul.31,2024

Valid until:Jul.30,2034

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Signify (China) Investment Co., Ltd.
Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Signify (China) Investment Co., Ltd.
Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

**NAME AND LOCATION
OF THE FACTORY**

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Surge protective devices connected to low-voltage power distribution systems
Surge 10kV protector class-I serial ;Surge 10kV protector class-II serial;See the Appendix

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T 18802.11-2020

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462111-2021.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO. : CQC24123440438

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

Type III (T3):

Type	Protection mode	U_{oc} (kV)	U_c (V)	U_p (kV)	Combination type
Surge 10kV Protector Class-I serial	L-N	10	305	1.5	/
	L-G	10	305	2.0	
	N-G	10	305	2.0	
Surge 10kV Protector Class-II serial	L-N	10	305	1.5	/



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE